

RFP 19-204
RFI #3

- Will Disconnects be required for basin heaters on all cooling towers?
Yes, a fusible service disconnect is required. The basin heaters may be a VE item at time of bid opening. A schedule of values is recommended.
- Is lightening protection required?
No
- Suwannee Middle School existing cooling towers have 2 speed motors. If VFD's are added is there a location in the plant to install?
The pre-bid meeting allowed all vendors to survey the sites inside and out to determine this.
- Will school cover the controls contractor?
No- Automated Logic is the Controls standard for the District.
- Is there a scope of work for controls?
No- The coordination and programing will be developed between the York Chiller panel controls and the EMS Controls tech, with input from the districts controls tech.